



LOWER VALLEY FIRE PROTECTION DISTRICT
PYROTECHNICS - FIREWORKS DISPLAY PERMIT

Note: Allow a minimum of ten (10) working days for review

Permit Valid Through

NAME OF SPONSORING PERSON, GROUP OR ORGANIZATION: EXACT LOCATION OF PRODUCTION:
NAME OF PYROTECHNICS/FIREWORKS OPERATOR: DATE AND TIME OF PRODUCTION:

CONTACT PERSON(S): CONTACT PHONE NUMBER(S):
NAME: ADDRESS:

FOR OFFICE USE ONLY

PLAN SUBMITTAL REQUIREMENTS SHALL INCLUDE THE FOLLOWING:
Ref: NFPA 160, 1123, 1124, 1126, 2018 edition of the IFC Section 5608 & Colorado 8 CCR 1507-12

- 1. NAME OF THE PERSON, GROUP OR ORGANIZATION SPONSORING THE PRODUCTION.
2. Date and time of day of the production.
3. Exact location of the production.
4. Name of person actually in charge of firing the pyrotechnics/fireworks.
5. Number, names, and ages of all assistants who are to be present.
6. Qualifications of the pyrotechnic/fireworks operator.
7. Pyrotechnic/Fireworks experience of the operator.
8. Confirmation of any applicable Colorado state and federal licenses held by the operator or assistant(s).
9. Evidence of the permittee's insurance carrier or financial responsibility.
10. Number and type of pyrotechnic/fireworks devices and materials to be used, the operators experience with those devices and effects, and a definition of the general responsibilities of assistants.
11. Diagram of the grounds or facilities where the production is to be held which shows the point at which pyrotechnic devices are to be fired, the fallout radius for each pyrotechnic device used in the performance, and the line behind which the audience is to be restrained.
12. Point of on-site assembly of pyrotechnic/fireworks devices.
13. Manner and storage of pyrotechnic/fireworks materials and devices.
14. Material safety data sheet (MSDS) for the pyrotechnic/fireworks materials to be used.
15. Certification that the set, scenery, and rigging materials are inherently flame-retardant or have been treated to achieve flame-retardancy.
16. Certification that all materials worn by performers in the fallout area during the use of pyrotechnic effects shall be inherently flame retardant or have been treated to achieve flame-retardancy.

NOTE: INDOOR USE OF CERTAIN PYROTECHNICS WHICH REQUIRE SMOKE DETECTORS TO BE BYPASSED OR AIR -HANDLING SYSTEM TO BE DISENGAGED IS NOT PERMITTED.

A WALK-THROUGH AND REPRESENTATIVE DEMONSTRATION (IF REQUIRED) OF THE PYROTECHNICS BEFORE THE PERMIT IS ISSUED MAY BE REQUIRED.

PYROTECHNICS SHOWS: A MINIMUM OF FOUR FIRE EXTINGUISHERS ARE REQUIRED: Two pressurized water, Class 2A and two Class 20-BC extinguishers. Extinguishers shall be placed so at least one of each Class is located on opposing sides of the performance.

SPECIAL REQUIREMENTS:
REVIEWER'S NAME: DATE:

I HAVE READ AND UNDERSTAND THE REVIEW COMMENTS INDICATED ABOVE AND REQUIREMENTS: Plan review fees are required per Resolution 05/8-2007b

Applicant's Signature Date
REV: 1/10/19